

## Room Relationship Matrix Domiciliary

	Circulation Spaces	Studio Unit	One Bedroom Unit	Vestibule / Entry	Living Room	Public Restrooms	Offices - Admin & Care	Dining
Circulation Spaces	NA	--	--	--	--	--	--	--
Studio Unit								
49 STC 1 HR	49 STC 1 HR	--	--	--	--	--	--	--
One Bedroom Unit								
49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	--	--	--	--	--	--
Vestibule / Entry				NA	--	--	--	--
45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	--	NA	--	--	--	--
Living Room								
49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	NA	--	--	--	--
Public Restrooms								
49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	NA	--	--	--
Offices - Admin & Care								
52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	NA	--	--
Dining								
49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	NA	--
Kitchen								
49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR	--
Kitchen Pantry								
49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	--
Kitchen Prep								
49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	--
Lifelong Learning Classroom								
49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	--
Concierge Wellness / Fitness								
49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR	--
Den								
49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR

### LEGEND

ROOM TYPE	ROOM TYPE
	PROXIMITY
	STC

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR 1-HOUR FIRE BARRIER  
 1.5 HR 1 1/2-HOUR FIRE BARRIER  
 2 HR 2-HOUR FIRE BARRIER  
 3 HR 3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

## Room Relationship Matrix Domiciliary

	Circulation Spaces	Studio Unit	One Bedroom Unit	Vestibule / Entry	Living Room	Public Restrooms	Offices - Admin & Care	Dining
Resident Laundry	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR
Mail Area	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR
Janitor Closet / Housekeeping	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR
Main Trash	STC 1 HR	49 STC 1 HR	49 STC 1 HR	STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR
Mechanical Area / Fire Pump	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Electrical Area / IT	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR
Storage	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR
Linen / Soiled Linen	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR
AV Closet	45 STC 0 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 0 HR

### LEGEND

ROOM TYPE	ROOM TYPE	
	PROXIMITY	
	STC	FIRE RATING
ADJACENT		
CONVENIENT		
NON-ADJACENT		

SM	SMOKE PARTITION (FIRE RATING NOT REQUIRED)
SC	SMOKE BARRIER (1 HR FIRE RATED MIN)
1 HR	1-HOUR FIRE BARRIER
1.5 HR	1 1/2-HOUR FIRE BARRIER
2 HR	2-HOUR FIRE BARRIER
3 HR	3-HOUR FIRE BARRIER

SM SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
SC SMOKE BARRIER (1 HR FIRE RATED MIN)  
1 HR 1-HOUR FIRE BARRIER  
1.5 HR 1 1/2-HOUR FIRE BARRIER  
2 HR 2-HOUR FIRE BARRIER  
3 HR 3-HOUR FIRE BARRIER

Revised 01/13/20  
Bridging Documents  
Amendment #3

## Room Relationship Matrix Domiciliary

	Kitchen	Kitchen Pantry	Kitchen Prep	Lifelong Learning Classroom	Concierge Wellness / Fitness	Den	Resident Laundry	Mail Area
Kitchen Pantry		NA	--	--	--	--	--	--
	52 STC 1 HR							
Kitchen Prep	52 STC 1 HR	52 STC 1 HR	NA	--	--	--	--	--
Lifelong Learning Classroom	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	NA	--	--	--	--
Concierge Wellness / Fitness	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	NA	--	--	--
Den	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	49 STC 1 HR	NA	--	--
Resident Laundry	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	NA	--
Mail Area	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	NA
Janitor Closet / Housekeeping	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Main Trash	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Mechanical Area / Fire Pump	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Electrical Area / IT	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Storage	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Linen / Soiled Linen	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR
AV Closet	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR

### LEGEND

ROOM TYPE	
ROOM TYPE	PROXIMITY
	STC
	FIRE RATING

ADJACENT
CONVENIENT
NON-ADJACENT

SM	SMOKE PARTITION (FIRE RATING NOT REQUIRED)
SC	SMOKE BARRIER (1 HR FIRE RATED MIN)
1 HR	1-HOUR FIRE BARRIER
1.5 HR	1 1/2-HOUR FIRE BARRIER
2 HR	2-HOUR FIRE BARRIER
3 HR	3-HOUR FIRE BARRIER

Revised 01/13/20  
Bridging Documents  
Amendment #3

## Room Relationship Matrix Domiciliary

	Janitor Closet / Housekeeping	Main Trash	Mechanical Area / Fire Pump	Electrical Area / IT	Storage	Linen / Soiled Linen	AV Closet
Janitor Closet / Housekeeping	NA	--	--	--	--	--	--
Main Trash	45 STC 1 HR	NA	--	--	--	--	--
Mechanical Area / Fire Pump	52 STC 1 HR	52 STC 1 HR	NA	--	--	--	--
Electrical Area / IT	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	NA	--	--	--
Storage	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	NA	--	--
Linen / Soiled Linen	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	NA	--
AV Closet	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	NA

### LEGEND

ROOM TYPE	ROOM TYPE
	PROXIMITY
	STC

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM                    SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC                    SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR                1-HOUR FIRE BARRIER  
 1.5 HR             1 1/2-HOUR FIRE BARRIER  
 2 HR                2-HOUR FIRE BARRIER  
 3 HR                3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3