

## Room Relationship Matrix Long Term Care - Household

	Circulation Spaces	Private Resident Room	Private Toilet Room	Living Room	Resident Dining Area	Resident Kitchenette / Serving	Pantry	Den / Quiet Room	Toilet Room
Circulation Spaces	NA	--	--	--	--	--	--	--	--
Private Resident Room	49 STC SM	49 STC 0 HR	--	--	--	--	--	--	--
Private Toilet Room	49 STC SM	49 STC 0 HR	49 STC 0 HR	--	--	--	--	--	--
Living Room	0 STC SM	49 STC SM	49 STC SM	NA	--	--	--	--	--
Resident Dining Area	0 STC SM	49 STC SM	49 STC SM	49 STC 0 HR	NA	--	--	--	--
Resident Kitchenette / Serving	0 STC SM	49 STC SM	49 STC SM	49 STC 0 HR	49 STC 0 HR	NA	--	--	--
Pantry	STC SM	49 STC 0 HR	49 STC 0 HR	49 STC SM	49 STC SM	49 STC SM	NA	--	--
Den / Quiet Room	55 STC SM	55 STC 0 HR	55 STC 0 HR	55 STC SM	55 STC SM	55 STC SM	55 STC 0 HR	NA	--
Toilet Room	49 STC SM	49 STC 0 HR	49 STC 0 HR	49 STC SM	49 STC SM	49 STC SM	49 STC 0 HR	55 STC 0 HR	NA
Clean Utility	49 STC SM	49 STC 1 HR	49 STC 1 HR	49 STC SM	49 STC SM	49 STC SM	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR
Soiled Utility	49 STC SM	49 STC 1 HR	49 STC 1 HR	49 STC SM	49 STC SM	49 STC SM	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR
Housekeeping Closet	45 STC SM	49 STC 0 HR	49 STC 0 HR	49 STC SM	49 STC SM	49 STC SM	49 STC 1 HR	55 STC 0 HR	49 STC 0 HR

### LEGEND

ROOM TYPE	
ROOM TYPE	
PROXIMITY	
STC	
FIRE RATING	

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR 1-HOUR FIRE BARRIER  
 1.5 HR 1 1/2-HOUR FIRE BARRIER  
 2 HR 2-HOUR FIRE BARRIER  
 3 HR 3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

## Room Relationship Matrix Long Term Care - Household

	Circulation Spaces	Private Resident Room	Private Toilet Room	Living Room	Resident Dining Area	Resident Kitchenette / Serving	Pantry	Den / Quiet Room	Toilet Room
<b>Spa (Tub Room) Training Toilet</b>	52 STC SM	52 STC 0 HR	52 STC 0 HR	52 STC SM	52 STC SM	52 STC SM	52 STC 1 HR	55 STC 0 HR	52 STC 0 HR
<b>Med Room</b>	49 STC SM	49 STC 0 HR	49 STC 0 HR	49 STC SM	49 STC SM	49 STC SM	49 STC 1 HR	55 STC 0 HR	49 STC 0 HR
<b>Nurse Office &amp; Charting Space</b>	52 STC SM	52 STC 0 HR	52 STC 0 HR	52 STC SM	52 STC SM	52 STC SM	1 STC 0 HR	55 STC 0 HR	52 STC 0 HR
<b>Equipment Storage Room</b>	45 STC SM	49 STC 1 HR	49 STC 1 HR	49 STC SM	49 STC SM	49 STC SM	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR
<b>Linen Closet</b>	45 STC 0 HR	49 STC SM	49 STC SM	49 STC 0 HR	49 STC 0 HR	49 STC SM	49 STC 1 HR	49 STC 0 HR	49 STC 0 HR
<b>Electrical Closet</b>	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	55 STC 1 HR	45 STC 1 HR
<b>Wheelchair Closet</b>	45 STC 0 HR	49 STC 0 HR	49 STC 0 HR	52 STC 0 HR	49 STC 0 HR	49 STC SM	49 STC 1 HR	55 STC 0 HR	49 STC 0 HR

### LEGEND

ROOM TYPE	
ROOM TYPE	PROXIMITY
	STC
	FIRE RATING

ADJACENT
CONVENIENT
NON-ADJACENT

SM	SMOKE PARTITION (FIRE RATING NOT REQUIRED)
SC	SMOKE BARRIER (1 HR FIRE RATED MIN)
1 HR	1-HOUR FIRE BARRIER
1.5 HR	1 1/2-HOUR FIRE BARRIER
2 HR	2-HOUR FIRE BARRIER
3 HR	3-HOUR FIRE BARRIER

Revised 01/13/20  
Bridging Documents  
Amendment #3

## Room Relationship Matrix Long Term Care - Household

	Clean Utility	Soiled Utility	Housekeeping Closet	Spa (Tub Room) Training Toilet	Med Room	Nurse Office & Charting Space	Equipment Storage Room	Linen Closet	Electrical Closet	Wheelchair Closet
Clean Utility	NA	--	--	--	--	--	--	--	--	--
Soiled Utility	45 STC 1 HR	NA	--	--	--	--	--	--	--	--
Housekeeping Closet	45 STC 1 HR	45 STC 1 HR	NA	--	--	--	--	--	--	--
Spa (Tub Room) Training Toilet	52 STC 1 HR	52 STC 1 HR		52 STC 0 HR	--	--	--	--	--	--
Med Room	45 STC 1 HR	45 STC 1 HR	45 STC 0 HR	52 STC 0 HR	NA	--	--	--	--	--
Nurse Office & Charting Space	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	NA	--	--	--	--
Equipment Storage Room	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	NA	--	--	--
Linen Closet	49 STC 1 HR	49 STC 1 HR	49 STC 0 HR	52 STC 0 HR	49 STC 0 HR	49 STC 0 HR	45 STC 1 HR	NA	--	--
Electrical Closet	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	49 STC 1 HR	45 STC 1 HR	45 STC 1 HR	NA	--
Wheelchair Closet	45 STC 1 HR	45 STC 1 HR	45 STC 0 HR	52 STC 0 HR	49 STC 0 HR	49 STC 0 HR	45 STC 1 HR	45 STC 0 HR	45 STC 1 HR	NA

### LEGEND

ROOM TYPE	
ROOM TYPE	PROXIMITY
	STC
	FIRE RATING

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM                    SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC                    SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR                1-HOUR FIRE BARRIER  
 1.5 HR             1 1/2-HOUR FIRE BARRIER  
 2 HR                2-HOUR FIRE BARRIER  
 3 HR                3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

## Room Relationship Matrix Long Term Care - Neighborhood Shared Amenity

	Circulation Spaces	Foyer	Nurses' Lounge w/ Toilet Room	Pantry	Resident Laundry	Multi purpose / Activity
Circulation Spaces	NA	--	--	--	--	--
Foyer	45 STC 0 HR	NA	--	--	--	--
Nurses' Lounge w/ Toilet Room	52 STC SM	52 STC 0 HR	NA	--	--	--
Pantry	49 STC SM	49 STC 0 HR	52 STC 0 HR	NA	--	--
Resident Laundry	49 STC SM	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR	NA	--
Multi purpose / Activity	52 STC SM	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	NA
Restorative Space	52 STC SM	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR
Barber / Beauty	52 STC SM	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR
3 Season Porch	52 STC SM	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR
Linen Holding	45 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR
IT Room	45 STC SM	49 STC 0 HR	49 STC 0 HR	45 STC 1 HR	45 STC 1 HR	52 STC 0 HR
Electrical Closet	45 STC SM	49 STC 0 HR	49 STC 0 HR	45 STC 1 HR	45 STC 1 HR	52 STC 0 HR

### LEGEND

ROOM TYPE	
ROOM TYPE	PROXIMITY
	STC
	FIRE RATING

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM                    SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC                    SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR                1-HOUR FIRE BARRIER  
 1.5 HR             1 1/2-HOUR FIRE BARRIER  
 2 HR                2-HOUR FIRE BARRIER  
 3 HR                3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

## Room Relationship Matrix Long Term Care - Neighborhood Shared Amenity

	Restorative Space	Barber / Beauty	3 Season Porch	Linen Holding	IT Room	Electrical Closet
Restorative Space	NA	--	--	--	--	--
Barber / Beauty	52 STC 0 HR	NA	--	--	--	--
3 Season Porch	52 STC 0 HR	52 STC 0 HR	NA	--	--	--
Linen Holding	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	NA	--	--
IT Room	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	45 STC 1 HR	NA	--
Electrical Closet	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	45 STC 1 HR	45 STC 0 HR	NA

### LEGEND

ROOM TYPE	ROOM TYPE		
	PROXIMITY		
	STC	FIRE RATING	

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM	SMOKE PARTITION (FIRE RATING NOT REQUIRED)
SC	SMOKE BARRIER (1 HR FIRE RATED MIN)
1 HR	1-HOUR FIRE BARRIER
1.5 HR	1 1/2-HOUR FIRE BARRIER
2 HR	2-HOUR FIRE BARRIER
3 HR	3-HOUR FIRE BARRIER

Revised 01/13/20  
Bridging Documents  
Amendment #3

# Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Circulation Spaces	Vestibule	Main Lobby	Reception	Coat Closet / WC Storage	Café / Coffee Shop	Pub	Classroom	Public Toilets	Beauty / Barber
Circulation Spaces	NA	--	--	--	--	--	--	--	--	--
Vestibule	45 STC 0 HR	NA	--	--	--	--	--	--	--	--
	45 STC HR		NA	--	--	--	--	--	--	--
Reception	45 STC HR	45 STC 0 HR	0 STC 0 HR	NA	--	--	--	--	--	--
	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR		NA	--	--	--	--	--
Coat Closet / WC Storage	45 STC 1 HR	45 STC 0 HR	45 STC 0 HR	45 STC 1 HR	NA	--	--	--	--	--
	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 1 HR		NA	--	--	--	--
Pub	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 1 HR	49 STC HR	NA	--	--	--
	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 1 HR	49 STC 0 HR		--	--	--
Classroom	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 1 HR	49 STC 0 HR	NA	--	--	--
	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 1 HR	49 STC 0 HR		--	--	--
Public Toilets	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 1 HR	49 STC 0 HR	49 STC 0 HR	NA	NA	NA
	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 1 HR	45 STC 0 HR	45 STC 0 HR			
Beauty / Barber	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 1 HR	45 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	NA
	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 1 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	
Club Room / Activity / Therapeutic	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 1 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	NA
	55 STC 0 HR	55 STC 0 HR	55 STC 0 HR	55 STC 0 HR	55 STC 1 HR	55 STC 0 HR	55 STC 0 HR	55 STC 0 HR	55 STC 0 HR	
Theater	55 STC 0 HR	55 STC 0 HR	55 STC 0 HR	55 STC 0 HR	55 STC 1 HR	55 STC 0 HR	55 STC 0 HR	55 STC 0 HR	55 STC 0 HR	55 STC 0 HR

## LEGEND

ROOM TYPE	ROOM TYPE		
	PROXIMITY		
	STC	FIRE RATING	
		ADJACENT	
		CONVENIENT	
		NON-ADJACENT	

ADJACENT  
 CONVENIENT  
 NON-ADJACENT

SM SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR 1-HOUR FIRE BARRIER  
 1.5 HR 1 1/2-HOUR FIRE BARRIER  
 2 HR 2-HOUR FIRE BARRIER  
 3 HR 3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

# Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Circulation Spaces	Vestibule	Main Lobby	Reception	Coat Closet / WC Storage	Café / Coffee Shop	Pub	Classroom	Public Toilets	Beauty / Barber
Business Center / Library	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 1 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR
Chapel / Meditation Space	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Chapel Storage	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Storage	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Director of Nursing	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Assistant Director of Nursing	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Infection Control Nurse	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Psych Nurse	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
1st Floor Supervisor	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
EHR/MDS Coordinator	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Staffing Coordinator	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Infection/ Inservice / Employee Health	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR

## LEGEND

ROOM TYPE	
ROOM TYPE	PROXIMITY
	STC
	FIRE RATING

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM	SMOKE PARTITION (FIRE RATING NOT REQUIRED)
SC	SMOKE BARRIER (1 HR FIRE RATED MIN)
1 HR	1-HOUR FIRE BARRIER
1.5 HR	1 1/2-HOUR FIRE BARRIER
2 HR	2-HOUR FIRE BARRIER
3 HR	3-HOUR FIRE BARRIER

Revised 01/13/20  
Bridging Documents  
Amendment #3

# Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Circulation Spaces	Vestibule	Main Lobby	Reception	Coat Closet / WC Storage	Café / Coffee Shop	Pub	Classroom	Public Toilets	Beauty / Barber
Work Room	52 STC 1 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 1 HR	49 STC 0 HR	49 STC 0 HR	52 STC 0 HR	49 STC 0 HR	49 STC 0 HR
Main Kitchen	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Dietary Director	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Central Storage	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Wheelchair storage and Cart Wash	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Resident Storage	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Activities Storage	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Soiled Linen Holding	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Clean Linen Holding	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Main Laundry	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR
Housekeeping Office	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Housekeeping	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR

## LEGEND

ROOM TYPE	ROOM TYPE	
	PROXIMITY	
	STC	FIRE RATING

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR 1-HOUR FIRE BARRIER  
 1.5 HR 1 1/2-HOUR FIRE BARRIER  
 2 HR 2-HOUR FIRE BARRIER  
 3 HR 3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

## Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Circulation Spaces	Vestibule	Main Lobby	Reception	Coat Closet / WC Storage	Café / Coffee Shop	Pub	Classroom	Public Toilets	Beauty / Barber
Mechanical Room / Fire Pump Room	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Electrical Room	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Emergency Switchgear	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Main IT Room (distribution)	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 1 HR	45 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	45 STC 0 HR
Main Pharmacy	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR	49 STC 1 HR
Trash Holding	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR
Staff Toilet / shower	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 1 HR	45 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	45 STC 0 HR
Maintenance Shop / BAS Hub	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 0 HR	45 STC 1 HR	45 STC 0 HR	49 STC 0 HR	49 STC 0 HR	49 STC 0 HR	45 STC 0 HR
Medical Records	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR
Oxygen Transfer	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	45 STC 1 HR

### LEGEND

ROOM TYPE	ROOM TYPE		
	PROXIMITY		
	STC	FIRE RATING	

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR 1-HOUR FIRE BARRIER  
 1.5 HR 1 1/2-HOUR FIRE BARRIER  
 2 HR 2-HOUR FIRE BARRIER  
 3 HR 3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

# Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Club Room / Activity / Therapeutic	Theater	Business Center / Library	Chapel / Meditation Space	Chapel Storage	Storage	Director of Nursing	Assistant Director of Nursing	Infection Control Nurse	Psych Nurse
Club Room / Activity / Therapeutic	NA	--	--	--	--	--	--	--	--	--
Theater	55 STC 0 HR	NA	--	--	--	--	--	--	--	--
Business Center / Library	49 STC 0 HR	55 STC 0 HR	NA	--	--	--	--	--	--	--
Chapel / Meditation Space	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	NA	--	--	--	--	--	--
Chapel Storage	49 STC 1 HR	55 STC 1 HR	45 STC 1 HR	52 STC 1 HR	NA	--	--	--	--	--
Storage	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR		NA	--	--	--	--
Director of Nursing	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	NA	--	--	--
Assistant Director of Nursing	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	NA	--	--
Infection Control Nurse	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	NA	--
Psych Nurse	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	NA
1st Floor Supervisor	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
EHR/MDS Coordinator	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR

## LEGEND

ROOM TYPE	
ROOM TYPE	PROXIMITY
	STC
	FIRE RATING

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR 1-HOUR FIRE BARRIER  
 1.5 HR 1 1/2-HOUR FIRE BARRIER  
 2 HR 2-HOUR FIRE BARRIER  
 3 HR 3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

# Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Club Room / Activity / Therapeutic	Theater	Business Center / Library	Chapel / Meditation Space	Chapel Storage	Storage	Director of Nursing	Assistant Director of Nursing	Infection Control Nurse	Psych Nurse
Staffing Coordinator										
	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Infection/ Inservice / Employee Health										
	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Work Room										
	49 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	49 STC 1 HR	49 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Main Kitchen										
	52 STC 1 HR	55 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Dietary Director										
	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Central Storage										
	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Wheelchair storage and Cart Wash										
	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Resident Storage										
	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Activities Storage										
	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Soiled Linen Holding										
	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Clean Linen Holding										
	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Main Laundry										
	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	49 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR

## LEGEND

ROOM TYPE	ROOM TYPE		
	PROXIMITY		
	STC	FIRE RATING	

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR 1-HOUR FIRE BARRIER  
 1.5 HR 1 1/2-HOUR FIRE BARRIER  
 2 HR 2-HOUR FIRE BARRIER  
 3 HR 3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

# Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Club Room / Activity / Therapeutic	Theater	Business Center / Library	Chapel / Meditation Space	Chapel Storage	Storage	Director of Nursing	Assistant Director of Nursing	Infection Control Nurse	Psych Nurse
Housekeeping Office	52 STC 0 HR	55 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Housekeeping	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Mechanical Room / Fire Pump Room	52 STC 1 HR	55 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Electrical Room	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Emergency Switchgear	52 STC 1 HR	55 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Main IT Room (distribution)	49 STC 0 HR	55 STC 0 HR	49 STC 0 HR	52 STC 0 HR	45 STC 1 HR	45 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Main Pharmacy	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Trash Holding	52 STC 1 HR	55 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Staff Toilet / shower	49 STC 0 HR	55 STC 0 HR	49 STC 0 HR	52 STC 0 HR	45 STC 1 HR	45 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Maintenance Shop / BAS Hub	49 STC 0 HR	55 STC 0 HR	49 STC 0 HR	52 STC 0 HR	45 STC 1 HR	45 STC 1 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR
Medical Records	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Oxygen Transfer	49 STC 1 HR	55 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR

## LEGEND

ROOM TYPE	
ROOM TYPE	PROXIMITY
	STC
	FIRE RATING

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR 1-HOUR FIRE BARRIER  
 1.5 HR 1 1/2-HOUR FIRE BARRIER  
 2 HR 2-HOUR FIRE BARRIER  
 3 HR 3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

# Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	1st Floor Supervisor	EHR/MDS Coordinator	Staffing Coordinator	Infection/ Inservice / Employee Health	Work Room	Main Kitchen	Dietary Director	Central Storage	Wheelchair storage and Cart Wash	Resident Storage
1st Floor Supervisor	NA	--	--	--	--	--	--	--	--	--
EHR/MDS Coordinator	52 STC 0 HR	NA	--	--	--	--	--	--	--	--
Staffing Coordinator	52 STC 0 HR	52 STC 0 HR	NA	--	--	--	--	--	--	--
Infection/ Inservice / Employee Health	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	NA	--	--	--	--	--	--
Work Room					NA	--	--	--	--	--
Main Kitchen	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	NA	--	--	--	--
Dietary Director	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	NA	--	--	--
Central Storage	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	NA	--	--
Wheelchair storage and Cart Wash	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	NA	--
Resident Storage	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	NA
Activities Storage	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Soiled Linen Holding	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR

## LEGEND

ROOM TYPE	ROOM TYPE	
	PROXIMITY	
	STC	FIRE RATING

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM	SMOKE PARTITION (FIRE RATING NOT REQUIRED)
SC	SMOKE BARRIER (1 HR FIRE RATED MIN)
1 HR	1-HOUR FIRE BARRIER
1.5 HR	1 1/2-HOUR FIRE BARRIER
2 HR	2-HOUR FIRE BARRIER
3 HR	3-HOUR FIRE BARRIER

Revised 01/13/20  
Bridging Documents  
Amendment #3

# Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	1st Floor Supervisor	EHR/MDS Coordinator	Staffing Coordinator	Infection/ Inservice / Employee Health	Work Room	Main Kitchen	Dietary Director	Central Storage	Wheelchair storage and Cart Wash	Resident Storage
Clean Linen Holding	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Main Laundry	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR
Housekeeping Office	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 1 HR	52 STC 0 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Housekeeping	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Mechanical Room / Fire Pump Room	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Electrical Room	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Emergency Switchgear	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR
Main IT Room (distribution)	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	49 STC 0 HR	52 STC 1 HR	52 STC 0 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Main Pharmacy	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Trash Holding	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Staff Toilet / shower	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	49 STC 0 HR	52 STC 1 HR	52 STC 0 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Maintenance Shop / BAS Hub	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	52 STC 0 HR	49 STC 0 HR	52 STC 1 HR	52 STC 0 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Medical Records	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Oxygen Transfer	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	49 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR

## LEGEND

ROOM TYPE	
ROOM TYPE	PROXIMITY
	STC
	FIRE RATING

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM	SMOKE PARTITION (FIRE RATING NOT REQUIRED)
SC	SMOKE BARRIER (1 HR FIRE RATED MIN)
1 HR	1-HOUR FIRE BARRIER
1.5 HR	1 1/2-HOUR FIRE BARRIER
2 HR	2-HOUR FIRE BARRIER
3 HR	3-HOUR FIRE BARRIER

Revised 01/13/20  
Bridging Documents  
Amendment #3

# Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Activities Storage	Soiled Linen Holding	Clean Linen Holding	Main Laundry	Housekeeping Office	Housekeeping	Mechanical Room / Fire Pump Room	Electrical Room	Emergency Switchgear	Main IT Room (distribution)
Activities Storage	NA	--	--	--	--	--	--	--	--	--
Soiled Linen Holding	45 STC 1 HR	NA	--	--	--	--	--	--	--	--
Clean Linen Holding	45 STC 1 HR	45 STC 1 HR	NA	--	--	--	--	--	--	--
Main Laundry	49 STC 1 HR	49 STC 1 HR	49 STC 1 HR	NA	--	--	--	--	--	--
Housekeeping Office	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	NA	--	--	--	--	--
Housekeeping	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	52 STC 1 HR	NA	--	--	--	--
Mechanical Room / Fire Pump Room	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	NA	--	--	--
Electrical Room	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	NA	--	--
Emergency Switchgear	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	NA	--
Main IT Room (distribution)	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	NA

## LEGEND

ROOM TYPE	
ROOM TYPE	PROXIMITY
	STC
	FIRE RATING

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM                    SMOKE PARTITION (FIRE RATING NOT REQUIRED)  
 SC                    SMOKE BARRIER (1 HR FIRE RATED MIN)  
 1 HR                1-HOUR FIRE BARRIER  
 1.5 HR             1 1/2-HOUR FIRE BARRIER  
 2 HR                2-HOUR FIRE BARRIER  
 3 HR                3-HOUR FIRE BARRIER

Revised 01/13/20  
 Bridging Documents  
 Amendment #3

## Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Activities Storage	Soiled Linen Holding	Clean Linen Holding	Main Laundry	Housekeeping Office	Housekeeping	Mechanical Room / Fire Pump Room	Electrical Room	Emergency Switchgear	Main IT Room (distribution)
Main Pharmacy	45 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR
Trash Holding										
	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR
Staff Toilet / shower										
	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	52 STC 0 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 0 HR
Maintenance Shop / BAS Hub										
	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	52 STC HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 0 HR
Medical Records										
	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR
Oxygen Transfer										
	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	49 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR	52 STC 1 HR	45 STC 1 HR

### LEGEND

ROOM TYPE	ROOM TYPE		
	PROXIMITY		
	STC	FIRE RATING	

	ADJACENT
	CONVENIENT
	NON-ADJACENT

SM	SMOKE PARTITION (FIRE RATING NOT REQUIRED)
SC	SMOKE BARRIER (1 HR FIRE RATED MIN)
1 HR	1-HOUR FIRE BARRIER
1.5 HR	1 1/2-HOUR FIRE BARRIER
2 HR	2-HOUR FIRE BARRIER
3 HR	3-HOUR FIRE BARRIER

Revised 01/13/20  
Bridging Documents  
Amendment #3

## Room Relationship Matrix Long Term Care - Community Center, Admin, Support Spaces Amenity

	Main Pharmacy	Trash Holding	Staff Toilet / shower	Maintenance Shop / BAS Hub	Medical Records	Oxygen Transfer
Main Pharmacy	NA	--	--	--	--	--
Trash Holding	45 STC 1 HR	NA	--	--	--	--
Staff Toilet / shower	45 STC 1 HR	45 STC 1 HR	NA	--	--	--
Maintenance Shop / BAS Hub	52 STC 1 HR	45 STC 1 HR	45 STC 0 HR	NA	--	--
Medical Records	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	NA	--
Oxygen Transfer	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	45 STC 1 HR	NA

### LEGEND

ROOM TYPE	ROOM TYPE
	PROXIMITY
	STC

ADJACENT
CONVENIENT
NON-ADJACENT

SM	SMOKE PARTITION (FIRE RATING NOT REQUIRED)
SC	SMOKE BARRIER (1 HR FIRE RATED MIN)
1 HR	1-HOUR FIRE BARRIER
1.5 HR	1 1/2-HOUR FIRE BARRIER
2 HR	2-HOUR FIRE BARRIER
3 HR	3-HOUR FIRE BARRIER

Revised 01/13/20  
Bridging Documents  
Amendment #3